



STEAM TRAP INSTALATION  
See ADPC.01.2167

DIMENSIONS ( mm )	
A	_____
B	_____
C	_____
D	_____
E	_____
F	_____
G	_____
H	_____

\* See IS catalogue

By pass should not be installed if there is the risk of damage due to over pressure.

8.1	01	ADCA MAN-100 Pressure gauge	DN_____	Range _____ - _____ bar	
08	01	ADCA MAN-100 Pressure gauge	DN_____	Range _____ - _____ bar	
07	02	ADCA GC-400 Gauge Cock	DN_____	---	
06	02	ADCA GSC-40 Gauge siphon	DN_____	---	
05	01	Safety valve	DN_____	Spring _____	
4.2	01	ADCA VF 16 Globe valve	DN_____	---	
4.1	01	ADCA VF 16 Globe valve	DN_____	---	
04	01	ADCA VF 16 Globe valve	DN_____	---	
03	01	ADCA IS16F Y Strainer	DN_____	---	
02	01	ADCA S25S Humidity separator	DN_____	---	
01	01	ADCA PRV47_____ Pressure reducing valve	DN_____	---	
Ref.	Quant.	Deseqanation / Designação	Size/Medidas	Material	Remarks / Observações

Data	06/07/07	Rubrica	F.Soarez	<b>VALSTEAM ADCA</b>	Proc.	0.490
Proj.	06/07/07					
Des.	06/07/07		Paulo S.			
Verif.						
Escalas	Tolerancias / Dimensões	especificadas / Desvios	PRESSURE REDUCING VALVE STATION CONJUNTO REDUTOR ARMADO <b>PRV47S</b>		Des.N°:	<b>ADCR.02.2375</b>
					Rev:	01