



WORKING CONDITIONS			
TUBE SIDE	STEAM		Bar
SHELL SIDE	WATER		°C
	Inlet	.	
	Outlet	.	°C
OUTPUT	.		Kw
Reg.		Yr. 200	

Nr.	Designation	Ref./DN	QTY	✓
1	ADCATHERM Heat exchanger		1	
2	ADCATROL PV16___/PV25___Control valve		1	
2.1	ADCA PE10 Electropneumatic positioner		1	
2.2	PT 100 pocket		1	
3	ADCA FLT Float & thermostatic steam trap		1	
4	ADCA FTL Float & thermostatic steam trap		1	
5	ADCA S25 Humidity separator		1	
6	ADCA IS16F Y strainer		1	
7	ADCA IS16 Y strainer		1	
8	ADCA DW40S Sigh glass		1	
9	ADCA SW12 Sigh glass		1	
10	ADCA RD40 Check valve		1	
11	ADCA RT25 Check valve		1	
12	ADCA PRV30 Pressure reducing valve		1	
13	ADCA VB21 Vacuum breaker		1	
14	ADCA AE16 Air eliminator		1	
15	ADCA GSC-40 Gauge siphon		1	
16	ADCA MAN-100 Pressure gauge		1	
17	ADCA GV32B Globe valve		1	
18	ADCA VF16 Globe valve		1	
19	Temperature indicator		1	
20	Safety valve		1	
21	Ball valve		2	
22	Circulating pump		1	
23	Expansion vessel		1	
24	Identification plate			

Data		Rubrica	Proc. 0.490
Proj.	09/11/05	F.Soares	
Des.	09/11/05	Paulo S.	
Verif.	---	F.Soares	
Escalas	Tolerancias / Dimensões	especificadas / Desvios	Description / Descrição: ADCATHERM "PWHU" Packaged Water Heating Unit Conj. produção de água quente
1/10			
			Des.N°: ADPWHU.01.2173
			Rev. 01 Em: 08/09/30